

September 14, 2015

United States Environmental Protection Agency
Region 5, WU-16J
77 West Jackson Blvd.
Chicago, Illinois 60604-3590
ATTN: UIC Branch, DI Section

Re: Written Report, EGT Injection Parameter Exceedance, Well # 2 Maximum Injection Flowrate
(in conformance with MI-163-1W-CO11, Part III.A, page 1 of 3)

Ladies & Gentlemen:

Environmental Geo-Technologies, LLC ("EGT") is writing this to inform you that an injection parameter, maximum injection flowrate, exceeded its maximum regulated rate (270 gpm) for one second @ 4:09 am on September 11, 2015 on Well #2. The condition that triggered the alarms was again a false positive signal, however, the actual operational parameter was not exceeded. The system corrected itself within one second, nevertheless, EGT is submitting this written report in conformance with its MI-163-1W-C011 EPA UIC permit.

The alarm system now appears to again be operating as it should. Nevertheless, as Corrective & Preventive Action ("CPA"), EGT has retained a computer consultant to attempt to rectify the issue.

This written report of this exceedance is timely [within five (5) working days] and in conformance with EGT's UIC Injection Permit # MI-163-1W-C011, Part 1.E.12.d.3 for the occurrence that occurred on 09.11.15 that was verbally reported to Mr. Allan Batka on 09.11.15 by this writer.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

We trust that you find this report satisfactory, however, if you have any questions or comments, please feel free to contact us.

Sincerely,

Richard J. Powals, P.E.
Vice President

cc: J. Frost (EGT), P. Sullivan (EGT), T. Athans (HH)

rjp091415/EGTEPAWell#2WrittenReport091415