



**REPUBLIC**  
SERVICES

28470 Citrin Drive Romulus, MI 48174  
o 734.946.1000 republicservices.com

December 30, 2021

Mr. Allan Batka  
United States Environmental Protection Agency  
Region 5 (WU-16J)  
77 West Jackson Blvd.

Re: RIES Monthly Report

Dear Mr. Batka:

Republic Industrial and Energy Solutions, LLC (RIES) hereby submits the Ninety Sixth Monthly Report ("MR") in conformance with the requirements of its two EPA UIC permits (#s MI-163-1W-C010 & MI-163-1W-C011). RIES is providing all the attached information in the same sequence as required by both subject permits, i.e. Part II. D.1 (a-i), Part III, Attachment A, and Part III, Attachment E.G.2 & E.I.

RIES did not accept F039 waste in November of 2021 so analyses as stated on Page A-3 of 3 of RIES's EPA two UIC permits are not required to be submitted as part of this MR. A short write-up is placed in sections Well 1 and Well 2 explaining the current state of chart recorder 3.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my supervision and interaction with the persons who manage and operate the system, and those persons responsible for the collection of the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

We trust that you find this report satisfactory, however, if you have any questions or comments, please feel free to contact us.

Sincerely,



John K. Frost

cc: Rick Sauve (Republic Services)

**AVERAGE INJECTION RATE**

**Calculation of Average Injection Rate**

CURRENT REPORTING YEAR 2021

CURRENT REPORTING MONTH November

Date (month, year) of the first injection into either well at the Citrin Road Facility  
Nov 2013

CURRENT MONTH (all volumes in gallons)

	Injected Waste	Injected Non-Waste	Total injected
<b>MI-163-1W-C010 , Well #1-12</b>			
Current Month	727,229	0	727,229
Since facility first injected			39,197,457
<b>MI-163-1W-C011, Well #2-12</b>			
Current Month	1,419,618	0	1,419,618
Since facility first injected			19,923,439
		Lifetime Combined	59,120,896

Conversion factors

365.25 days per year ÷ 12 months per year = 30.4375 days per month

30.4375 days per month × 1440 minutes per day = 43,830 minutes per month

Calculations

Whole number of months of injection 95

95 lifetime number of months of injection × 43,830 minutes/month  
= 4,163,850 minutes of injection

Lifetime combined injected volume  $\frac{59,120,896}{4,163,850}$  minutes of injection  
= 14.20 gpm average injection rate

**WELL 1 DATA**



Injection Well 1, November 2021

	Injection Pressure (psig)		Annulus Tank Level (inch)		Annulus Pressure (psig)		Injection pH		Flow Rate (gpm)		Differential Pressure (psig)	
	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
11/1/2021	121.4	134.2	31.2	31.3	852.2	855.2	2.0	7.0	0.0	0.0	719.4	731.7
11/2/2021	128.6	137.8	31.2	31.3	849.4	854.2	6.4	7.0	0.0	0.0	711.7	721.8
11/3/2021	113.7	784.4	31.2	31.2	732.3	1,189.3	1.7	7.4	0.0	76.4	316.2	737.2
11/4/2021	71.6	886.3	30.0	31.2	726.1	1,457.8	1.3	13.3	0.0	80.7	214.5	828.1
11/5/2021	68.2	896.0	30.0	30.0	1,031.8	1,478.0	1.5	12.8	0.0	79.6	465.5	993.1
11/6/2021	51.4	885.1	30.0	30.0	962.9	1,489.9	1.3	9.1	0.0	79.6	441.5	1,007.0
11/7/2021	145.0	157.3	30.0	30.0	1,067.0	1,084.3	5.5	5.8	0.0	0.0	909.9	938.1
11/8/2021	142.9	953.8	30.0	30.1	1,081.1	1,498.5	2.1	14.2	0.0	80.9	417.1	938.9
11/9/2021	98.1	939.8	30.1	30.1	996.8	1,468.5	1.7	9.9	0.0	81.7	405.6	947.3
11/10/2021	99.0	806.3	30.1	30.1	972.2	1,443.8	2.4	9.4	0.0	83.0	502.6	999.0
11/11/2021	135.4	908.7	30.0	30.2	1,094.6	1,538.2	3.3	14.0	0.0	89.0	600.8	988.7
11/12/2021	-7.1	941.7	30.1	30.3	1,070.0	1,500.3	6.7	14.0	0.0	162.5	528.9	1,108.9
11/13/2021	136.1	875.5	30.1	30.2	1,097.3	1,484.1	6.6	7.0	0.0	74.5	588.5	993.8
11/14/2021	124.5	143.7	29.9	30.1	1,059.7	1,099.0	6.8	6.8	0.0	0.0	934.5	955.8
11/15/2021	121.2	130.6	29.9	30.0	1,051.9	1,061.2	6.8	13.1	0.0	0.0	921.5	936.7
11/16/2021	115.7	133.8	29.9	30.0	1,046.5	1,053.3	1.5	7.0	0.0	0.0	913.0	932.1
11/17/2021	78.0	134.7	30.0	30.1	1,041.6	1,047.9	1.7	7.0	0.0	0.0	907.2	954.3
11/18/2021	127.7	135.2	29.9	30.1	1,035.6	1,043.0	4.7	6.9	0.0	0.0	901.3	910.7
11/19/2021	88.7	135.2	29.8	30.1	1,030.4	1,036.6	5.5	7.6	0.0	0.0	896.2	932.1
11/20/2021	81.5	839.6	30.0	30.1	909.4	1,250.5	1.5	7.6	0.0	97.4	385.5	941.7
11/21/2021	97.6	107.2	30.1	30.1	995.8	1,005.3	1.8	2.0	0.0	0.0	888.7	906.3
11/22/2021	80.1	107.8	30.1	30.2	1,001.0	1,005.3	2.0	6.2	0.0	0.0	895.9	924.6
11/23/2021	37.0	110.8	30.1	30.2	1,000.2	1,005.0	2.0	6.2	0.0	0.0	890.0	919.6
11/24/2021	37.6	113.3	30.1	30.2	997.2	1,001.4	2.4	7.0	0.0	0.0	884.4	963.7
11/25/2021	98.8	113.5	30.1	30.2	986.3	998.2	6.9	7.0	0.0	0.0	883.7	888.4
11/26/2021	94.8	102.4	30.1	30.2	980.4	987.0	4.3	7.0	0.0	0.0	882.2	888.7
11/27/2021	81.9	100.6	30.0	30.1	974.4	981.1	4.4	4.4	0.0	0.0	878.1	900.7
11/28/2021	63.3	98.9	30.0	30.1	968.9	975.3	4.3	4.4	0.0	0.0	874.3	898.3
11/29/2021	71.1	103.9	30.0	30.1	966.7	969.6	3.4	10.9	0.0	0.0	865.1	914.7
11/30/2021	37.9	107.5	30.1	30.2	965.3	969.5	6.5	6.9	0.0	0.0	858.0	898.6

## Circle Chart Index

Republic Industrial Energy Solutions, LLC 28470 Citrin Drive Romulus, MI 48174

### Chart Recorder #1

Channel #1

**Blue Pen** - Well 1 Injection Pressure (chart value x 30)

Channel #2

**Red Pen** — Well 1 Annulus Pressure (chart value x 30)

Channel #3

**Green Pen** — Well 1 Flow Rate (chart value x 4)

Channel #4

**Black Pen** — Well 1 Annulus Tank Level (chart value x 0)

### Chart Recorder #2

Channel #1

**Blue Pen** — Well 2 Injection Pressure (chart value x 30)

Channel #2

**Red Pen** — Well 2 Annulus Pressure (chart value x 30)

Channel #3

**Green Pen** — Well 2 Flow Rate (chart value x 4)

Channel #4

**Black Pen** — Well 2 Annulus Tank Level (chart value x 0)

### Chart Recorder #3

Channel #1

**Blue Pen** — Injection pH Well 1 & 2 (chart value 3.3)

Channel #2


**Red Pen** — Well 1 Monthly Volume (chart value x 100,000)

Channel #3

**Green Pen** — Well 2 Monthly Volume (chart value x 100,000)


channel *tm*

**Black Pen** — Temperature (chart value x 0)



Graphic Controls LLC


DATE CRI 11-17-21  
TA 500P1225-2



Graphic Controls LLC

DATE CRI 11-24-21  
TA 500PI225-2





Graphic Controls LLC

DATE 11-3-21 CRA  
TA 500P1225-2

**WELL 2 DATA**



Injection Well 2, November 2021

	Injection Pressure (psig)		Annulus Tank Level (inch)		Annulus Pressure (psig)		Injection pH		Flow Rate (gpm)		Differential Pressure (psig)	
	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
11/1/2021	113.6	761.7	34.1	34.2	794.8	1,201.1	1.5	7.0	0.0	84.8	339.6	744.8
11/2/2021	71.3	771.1	34.1	34.2	819.0	1,177.5	1.7	10.2	0.0	81.6	226.8	766.1
11/3/2021	24.7	668.3	34.1	34.2	738.0	1,042.3	1.7	7.6	0.0	76.4	332.7	778.9
11/4/2021	35.0	48.2	34.1	34.2	816.0	823.9	1.3	13.3	0.0	0.0	775.3	782.8
11/5/2021	38.1	52.3	34.1	34.2	822.9	827.9	1.5	12.8	0.0	0.0	775.1	785.2
11/6/2021	43.8	53.1	34.1	34.2	823.9	828.2	1.3	9.1	0.0	0.0	773.9	781.3
11/7/2021	39.3	46.6	34.1	34.1	820.1	824.5	5.5	5.8	0.0	0.0	777.5	781.4
11/8/2021	38.6	54.1	34.1	34.3	819.3	826.3	2.1	14.2	0.0	0.0	771.4	781.4
11/9/2021	49.6	61.7	34.2	34.3	823.5	827.7	1.7	9.9	0.0	0.0	765.4	774.5
11/10/2021	56.5	799.1	34.2	34.3	822.4	1,227.8	2.4	9.4	0.0	77.9	329.6	768.7
11/11/2021	114.5	860.0	34.1	34.4	831.8	1,306.3	3.3	14.0	0.0	86.1	328.3	731.5
11/12/2021	46.1	938.1	34.3	34.4	863.1	1,291.9	6.7	14.0	0.0	97.9	319.0	820.0
11/13/2021	143.6	840.5	34.2	34.4	886.8	1,268.6	6.6	7.0	0.0	84.4	391.8	773.4
11/14/2021	123.1	144.1	34.0	34.3	851.9	887.1	6.8	6.8	0.0	0.0	728.1	743.4
11/15/2021	120.2	887.2	34.0	34.1	848.2	1,238.3	1.1	13.2	0.0	83.3	237.3	729.3
11/16/2021	133.7	820.8	33.0	34.1	879.0	1,484.6	1.4	9.7	0.0	87.2	190.9	885.3
11/17/2021	98.2	848.9	33.1	33.3	901.8	1,480.3	1.5	13.2	0.0	87.0	368.7	914.0
11/18/2021	100.9	888.2	33.0	33.3	989.4	1,386.6	2.0	10.7	0.0	81.4	417.1	937.2
11/19/2021	126.0	868.2	32.9	33.2	972.7	1,348.1	2.2	7.6	0.0	84.6	435.9	903.4
11/20/2021	110.8	876.4	33.2	33.3	947.2	1,349.4	1.6	7.6	0.0	216.2	430.5	918.1
11/21/2021	97.6	111.5	33.2	33.3	1,028.6	1,049.6	1.8	2.0	0.0	0.0	917.2	951.9
11/22/2021	95.8	761.3	33.2	33.3	1,044.8	1,272.4	2.0	13.4	0.0	98.2	493.2	954.1
11/23/2021	79.5	841.9	33.2	33.3	940.4	1,329.6	2.0	13.4	0.0	82.6	399.5	913.6
11/24/2021	47.3	864.2	33.2	33.4	930.1	1,375.0	1.9	7.0	0.0	99.2	419.7	941.5
11/25/2021	148.2	864.3	33.3	33.4	979.5	1,282.3	3.7	4.6	0.0	0.0	413.4	901.5
11/26/2021	116.4	828.9	33.2	33.3	1,049.1	1,375.4	4.4	7.1	0.0	93.4	540.6	933.1
11/27/2021	112.5	815.7	33.1	33.2	1,045.8	1,355.0	7.0	7.1	0.0	90.5	537.9	933.9
11/28/2021	110.1	789.3	33.1	33.2	1,038.8	1,331.6	7.0	7.1	0.0	100.5	531.3	934.0
11/29/2021	109.8	847.2	33.1	33.3	1,041.0	1,353.1	2.9	13.0	0.0	99.0	506.4	931.8
11/30/2021	45.3	867.7	33.2	33.3	1,053.3	1,456.5	0.7	12.6	0.0	87.1	491.5	1,023.8

## Circle Chart Index

Republic Industrial Energy Solutions, LLC 28470 Citrin Drive Romulus, MI 48174

### Chart Recorder #1

Channel #1

**Blue Pen** - Well 1 Injection Pressure (chart value x 30)

Channel #2

**Red Pen** — Well 1 Annulus Pressure (chart value x 30)

Channel #3

**Green Pen** — Well 1 Flow Rate (chart value x 4)

Channel #4

**Black Pen** — Well 1 Annulus Tank Level (chart value x 0)

### Chart Recorder #2

Channel #1

**Blue Pen** — Well 2 Injection Pressure (chart value x 30)

Channel #2

**Red Pen** — Well 2 Annulus Pressure (chart value x 30)

Channel #3

**Green Pen** — Well 2 Flow Rate (chart value x 4)

Channel #4

**Black Pen** — Well 2 Annulus Tank Level (chart value x 0)

### Chart Recorder #3

Channel #1

**Blue Pen** — Injection pH Well 1 & 2 (chart value 3.3)

Channel #2


**Red Pen** — Well 1 Monthly Volume (chart value x 100,000)

Channel #3

**Green Pen** — Well 2 Monthly Volume (chart value x 100,000)

channel *tm*

**Black Pen** — Temperature (chart value x 0)



Graphic Controls LLC

DATE CB2 11-24-21  
TA 500P1225-2

SUNDAY  
NOON

6 P.M.

MID NIGHT

3 A.M.

NOON

6 P.M.

MID NIGHT

3 A.M.

9

3

9

3

6

9

3

6

9

3

6

9

9

6

3

0

3

6

9

12

3

6

9

12

3

6

9

12

3

6

9

12

3

6

9

12

3

9

6

3

0

3

6

9

12

3

6

9

12

3

6

9

12

3

6

9

12

3

6

9

12

3

9

6

3

0

3

6

9

12

3

6

9

12

3

6

9

12

3

6

9

12

3

6

9

12

3

9

6

3

0

3

6

9

12

3

6

9

12

3

6

9

12

3

6

9

12

3

6

9

12

3

FRIDAY  
NOON

6 P.M.

MID NIGHT


3 A.M.

THURSDAY  
NOON

6 P.M.


MID NIGHT

3 A.M.



Graphic Controls LLC

DATE CR2 11-17-21  
TA 500P1225-2



Graphic Controls LLC

DATE 1-3-21 CR2  
TA 500P1225-2

## Circle Chart Recorder #3

Circle chart recorder #3 is broken and a replacement is on order. Upon reception of a replacement recorder, installation will be performed by Utility Instrumentation Services. Circle chart recorders #1 and #2 have been replaced by Utility Instrumentation Services in September 2021. Continuous monitoring data is being recorded and backed up on a hard drive system. Upon request from the EPA the data can be accessed and provided for any reporting month. Otherwise, the data recorded every 10 seconds throughout the month would take 259,000 lines of data and more than 2000 extra pages to be added to this report.



## **CORROSION MONITORING**

**CORROSION MONITORING PLAN  
COUPON SUMMARY**

Date	Hastelloy (C267)	Stainless Steel (316L)	Fiberglass (Redbox)	
12/19/2013	13.330 g	10.848 g	7.309 g	Initial Mass @ start up
2/21/2014	13.329 g	10.846 g	7.306 g	
3/10/2014	13.327 g	10.845 g	7.300 g	
4/18/2014	13.324 g	10.841 g	7.272 g	
5/30/2014	13.328 g	10.818 g	7.226 g	
6/30/2014	13.321 g	10.337 g	7.196 g	
7/11/2014	13.323 g	10.304 g	7.196 g	
8/12/2014	13.328 g	10.045 g	7.182 g	
9/17/2014	13.321 g	9.997 g	7.090 g	
10/30/2014	13.321 g	9.387 g	7.075 g	
11/21/2014	13.320 g	9.386 g	7.069 g	
12/19/2014	13.321 g	9.315 g	7.084 g	
1/12/2015	13.321 g	9.289 g	7.063 g	New hastelloy coupon
2/23/2015	13.339 g	9.286 g	7.005 g	
3/31/2015	13.339 g	9.286 g	7.005 g	
4/27/2015	13.335 g	9.130 g	6.852 g	
5/21/2015	13.336 g	9.124 g	6.809 g	
6/12/2015	13.334 g	9.126 g	6.819 g	
7/27/2015	13.337 g	9.127 g	6.818 g	
8/26/2015	13.337 g	9.022 g	6.780 g	
9/21/2015	13.336 g	8.987 g	6.792 g	
10/19/2015	13.335 g	8.985 g	6.797 g	
11/16/2015	13.334 g	8.982 g	6.788 g	
12/17/2015	13.334 g	8.933 g	6.791 g	
1/29/2016	13.334 g	8.931 g	6.788 g	New stainless steel coupon
2/16/2016	13.332 g	8.799 g	6.757 g	
3/31/2016	13.339 g	9.286 g	7.005 g	
4/22/2016	13.333 g	8.590 g	6.744 g	
5/31/2015	13.334 g	6.084 g	6.784 g	
6/30/2016	13.328 g	10.942 g	6.793 g	
8/3/2016	13.326 g	10.529 g	6.743 g	
8/29/2016	13.325 g	10.020 g	6.723 g	
10/27/2016	13.325 g	8.765 g	6.708 g	
11/29/2016	13.327 g	8.571 g	6.740 g	
12/12/2016	13.323 g	8.223 g	6.717 g	
1/3/2017	13.325 g	8.059 g	6.712 g	
2/28/2017	13.324 g	7.634 g	6.727 g	New Fiberglass coupon
3/24/2017	13.325 g	7.370 g	6.732 g	
4/28/2017	13.325 g	6.736 g	6.736 g	
5/11/2017	13.323 g	7.352 g	6.689 g	
6/12/2017	13.323 g	7.357 g	6.689 g	
7/5/2017	13.323 g	7.355 g	6.689 g	
8/30/2017	13.324 g	7.353 g	18.105 g	
9/28/2017	13.325 g	7.352 g	18.060 g	
10/11/2017	13.324 g	7.350 g	18.038 g	
11/16/2017	13.325 g	7.363 g	18.047 g	
12/12/2017	13.326 g	7.308 g	18.307 g	

**CORROSION MONITORING PLAN  
COUPON SUMMARY**

Date	Hastelloy	Stainless Steel	Fiberglass	
1/29/2018	13.326 g	10.930 g	18.027 g	New stainless steel coupon
2/9/2018	13.325 g	10.932 g	18.044 g	
3/19/2018	13.325 g	10.926 g	18.030 g	
4/16/2018	13.336 g	10.863 g	18.068 g	
5/17/2018	13.325 g	10.858 g	18.037 g	
6/20/2018	13.325 g	10.855 g	18.029 g	
7/12/2018	13.326 g	10.852 g	18.032 g	
8/21/2018	13.326 g	10.854 g	18.031 g	
9/14/2018	13.326 g	10.852 g	18.036 g	
10/10/2018	13.326 g	10.851 g	18.031 g	
11/20/2018	13.326 g	10.853 g	18.032 g	
12/11/2018	13.326 g	10.852 g	18.033 g	
1/14/2019	13.326 g	10.852 g	18.033 g	
2/20/2019	13.326 g	10.850 g	18.033 g	
3/15/2019	13.326 g	10.850 g	18.033 g	
4/10/2019	13.326 g	10.848 g	18.031 g	
5/17/2019	13.326 g	10.849 g	18.036 g	
6/5/2019	13.326 g	10.848 g	18.031 g	
7/8/2019	13.326 g	10.845 g	18.032 g	
8/12/2019	13.326 g	10.845 g	18.032 g	
9/8/2019	13.326 g	10.842 g	18.029 g	
10/17/2019	13.326 g	10.842 g	18.030 g	
11/20/2019	13.326 g	10.842 g	18.030 g	
12/11/2019	13.326 g	10.842 g	18.030 g	
1/16/2020	13.326 g	10.840 g	18.033 g	
2/6/2020	13.326 g	10.836 g	18.034 g	
3/3/2020	13.326 g	10.842 g	18.034 g	Well 1 workover new well
4/9/2020	13.328 g	10.839 g	18.037 g	
5/12/2020	13.322 g	10.830 g	18.035 g	
6/16/2020	13.316 g	10.771 g	18.009 g	
7/16/2020	13.308 g	10.560 g	17.843 g	
8/25/2020	13.310 g	10.214 g	17.773 g	
9/24/2020	13.289 g	9.796 g	17.656 g	
10/19/2020	13.282g	9.737g	17.621g	
11/5/2020	13.280g	9.728g	17.600g	
12/3/2020	13.281g	9.730g	17.689g	
2/10/2021	13.284g	9.728g	17.683g	
3/9/2021	13.290g	9.733g	17.585g	
4/13/2021	13.288g	9.730g	17.649g	
5/18/2021	13.282g	9.691g	17.543g	
6/17/2021	13.279g	9.639g	17.546g	
7/19/2021	13.278g	9.480g	17.507g	
8/3/2021	13.278g	9.437g	17.467g	
9/14/2021	13.277g	9.392g	17.467g	
10/11/2021	13.277g	9.359g	17.465g	
11/3/2021	13.277g	9.350g	17.273g	

Date: 11/03/2021  
Material: C1563 / 316L  
Weight: 9.350 g.



Date: 11/03/2021  
Material: C276 5  
Weight: 13.277 g.



Date: 11/03/2021  
Material: Fiberglass  
Weight: 17.273 g.



# CORROSION MONITORING COUPONS BASELINE VISUAL DESCRIPTION

November 4, 2013

## Fiberglass

The fiberglass coupon is Red Box 2000 type and is 2-1/2 inches long by 1/2 inch wide and 1/4 inches thick. It is a dark orange (rust) in color with a glossy shine on one side a polished look on the opposite side and the cut edges look sanded.

## Hastelloy

The hastelloy coupon is identified as C276 with serial number 1. The dimensions of the coupon are 3 inches long by 1/2 inch wide and 1/4 inch thick. The coupon is silver in color with a lightly sandblasted surface.

## Stainless Steel

The stainless steel coupon is identified as 316L with serial number C1562. The dimensions of the coupon are 3 inches long by 1/2 inch wide and 1/4 inch thick. The coupon is silver in color with a lightly sandblasted surface.



AKRON RUBBER DEVELOPMENT LABORATORY, INC.

Progress Through Innovation, Technology and Customer Satisfaction

October 22, 2015

# • TEST REPORT •

**PN 125322**

*PO 00154*

## PLASTICS TESTING DEPARTMENT

Prepared For:

John Frost  
Environmental Geo-Technologies, LLC  
28470 Citrin Drive  
Romulus, MI 48174

Prepared By:

Melissa Martin  
*Sr. Project Technician*

Approved By:

Jim Drummond, Sr.  
*Physical & Plastic Testing, Manager*



**ACCREDITED**  
A Testing Lab

\*Certificate Numbers 255.01 & 255.02

An A2LA ISO 17025 Accredited Testing Laboratory — Certificate Numbers 255.01 & 255.02  
ISO 9001:2008 Registered

**ISO 9001:2008**  
Registered

Letters and reports are for the exclusive use of the clients to whom they are addressed and shall not be reproduced, except in full, without the written permission of Akron Rubber Development Laboratory, Inc. (ARDL). The information contained herein applies to the specific material, products or processes tested or evaluated. No warranty of any kind is herein construed or implied. The liability of ARDL, Inc. shall be limited to the amount of consideration paid for services. ARDL, Inc. is ISO 17025 accredited by A2LA for the test methods listed on the attached scope.

www.ardl.com | 2887 Gilchrist Rd. | Akron, Ohio 44305 | answers@ardl.com | Toll Free (800) 830-ARDL

Fax (330) 794-6610 | Worldwide (330) 794-6600



October 22, 2015

John Frost  
Environmental Geo-Technologies, LLC

Page 2 of 2  
PN 125322

**SUBJECT:** Barcol Hardness on one material.

**RECEIVED:** One small section identified as; Fiberglass Coupon.


**BARCOL HARDNESS ASTM D 2583-13a**  
Instant Reading

**Results**

Barcol Hardness, Instant


96

Prepared By:

  
Melissa Martin  
Sr. Project Technician

tc

Approved By:

  
Scott W. Yates  
Plastics Testing Assistant Manager



AKRON RUBBER DEVELOPMENT LABORATORY, INC.

Progress Through Innovation, Technology and Customer Satisfaction

December 12, 2016

# TEST REPORT


PN 132662  
PO

## PLASTICS TESTING DEPARTMENT

Prepared For:


John Frost  
Environmental Geo-Technologies, LLC  
28470 Citrin Drive  
Romulus, MI 48174

Prepared By:

  
Melissa Martin  
Senior Project Technician

Rev 041916

Approved By:

  
Jim Drummond  
Physical Testing, Manager



An A2LA ISO 17025 Accredited Testing Laboratory — Certificate Numbers 255.01 & 255.02  
ISO 9001:2008 Registered

**ISO 9001:2008**  
Registered

Letters and reports are for the exclusive use of the clients to whom they are addressed and shall not be reproduced, except in full, without the written permission of Akron Rubber Development Laboratory, Inc. (ARDL). The information contained herein applies to the specific material, products or processes tested or evaluated. No warranty of any kind is herein construed or implied. The liability of ARDL, Inc. shall be limited to the amount of consideration paid for services. ARDL, Inc. is ISO 17025 accredited by A2LA for the test methods listed on the referenced certificates.





December 12, 2016

John Frost  
Environmental Geo-Technologies, LLC

Page 2 of 2  
PN 132662

**SUBJECT:** Barcol Hardness on one (1) material.


**RECEIVED:** One (1) small section identified as; Fiberglass Coupon.

**BARCOL HARDNESS ASTM D 2583-13a**  
Instant Reading


RESULTS

Barcol Hardness, Instant 96

Prepared By:

  
Melissa Martin  
Senior Project Technician

Approved By:

  
Scott Yates  
Plastics Testing, Assistant Manager

wk

*\*ARDL is ISO 17025 accredited by A2LA for the test methods listed on the certificates referenced on page one. NOTE: Non-ISO 17025 accredited test methods are designated with the ^ symbol to differentiate from ISO 17025 accredited methods in the body of the test report.\**

December 13, 2017

**TEST REPORT**

**PN 139140**

*PO#*

**PLASTIC TESTING DEPARTMENT**

Prepared For:

John Frost  
Environmental Geo-Technologies, LLC  
28470 Citrin Drive  
Romulus, MI 48174

Prepared By:

Melissa Martin  
*Sr Project Technician*

Approved By:

Jim Drummond  
*Rubber & Plastic Testing, Manager*

Rev 041916



An A2LA ISO 17025 Accredited Testing Laboratory — Certificate Numbers 255.01 & 255.02  
ISO 9001:2008 Registered

**ISO 9001:2008**  
Registered

Letters and reports are for the exclusive use of the clients to whom they are addressed and shall not be reproduced, except in full, without the written permission of Akron Rubber Development Laboratory, Inc. (ARDL). The information contained herein applies to the specific material, products or processes tested or evaluated. No warranty of any kind is herein construed or implied. The liability of ARDL, Inc. shall be limited to the amount of consideration paid for services. ARDL, Inc. is ISO 17025 accredited by A2LA for the test methods listed on the referenced certificates.



December 13, 2017

John Frost  
Environmental Geo-Technologies, LLC

Page 2 of 2  
PN 139140

**SUBJECT:** Barcol Hardness on one material.

**RECEIVED:** One small section identified as; Fiberglass Coupon.

**BARCOL HARDNESS ASTM D 2583-13a**  
Instant Reading

**Results**

Barcol Hardness, Instant


96

Prepared By:



Melissa Martin  
Sr Project Technician

Approved By:



Scott Yates  
Plastics Testing, Assistant Manager

sc

\*ARDL is ISO 17025 accredited by A2LA for the test methods listed on the certificates referenced on page one. NOTE: Non-ISO 17025 accredited test methods are designated with the ^ symbol to differentiate from ISO 17025 accredited methods in the body of the test report.\*

# Ghesquiere Plastic Testing, Inc.

20450 HARPER AVENUE  
HARPER WOODS, MI 48225  
PHONE (313) 885-3535  
FAX (313) 885-1771

Report Date: November 15, 2013  
Test Date: October 15 - November 14, 2013

Report #1310-77651  
Performed for:  
Environmental Geo-Technologies  
28470 Citrin Drive  
Romulus, MI 48174

Attention: Mr. Don Anderson

WORK REQUESTED:

Perform Barcol Hardness test on sample submitted.

DESCRIPTION OF SAMPLE:

Sample submitted was identified as a fiberglass test coupon.

(P. O. #Credit Card).

WORK PERFORMED:

Test specimen was prepared as necessary and conditioned for a minimum of 24 hours at standard laboratory conditions prior to testing.

Barcol Hardness test was performed in accordance with the procedures of ASTM D2583-13. One specimen was tested.

RESULTS:


The following determination was made based upon the above test:

BARCOL HARDNESS

	<u>Hardness</u>
Specimen 1	90

Specimen is being returned with this report for further evaluation.

Ghesquiere Plastic Testing, Inc.

  
M. W. Ghesquiere  
President

MWG/kni

# Ghesquiere Plastic Testing, Inc.

20450 HARPER AVENUE  
HARPER WOODS, MI 48225  
PHONE (313) 885-3535  
FAX (313) 885-1771

Report Date: February 17, 2014  
Test Date: February 14 - 17, 2014

Report #1402-78036  
Performed for:  
Environmental Geo-Technologies  
28470 Citrin Drive  
Romulus, MI 48174

Attention: Mr. Don Anderson

## WORK REQUESTED:

Perform Barcol Hardness test on sample submitted.

## DESCRIPTION OF SAMPLE:

Sample submitted was identified as a fiberglass test coupon.  
(P. O. #Credit Card).

## WORK PERFORMED:

Test specimen was prepared as necessary and conditioned for a minimum of 24 hours at standard laboratory conditions prior to testing.

Barcol Hardness test was performed in accordance with the procedures of ASTM D2583-13. One specimen was tested.

## RESULTS:

The following determination was made based upon the above test:

### BARCOL HARDNESS

#### Hardness

Specimen 1: 90

Specimen was returned to the client on February 17, 2014.

Ghesquiere Plastic Testing, Inc.

M. W. Ghesquiere  
President

MWG/dm

# Ghesquiere Plastic Testing, Inc.

20450 HARPER AVENUE  
HARPER WOODS, MI 48225  
PHONE (313) 885-3535  
FAX (313) 885-1771

Report Date: June 16, 2014  
Test Date: June 13 - 16, 2014

Report #1406-78499  
Performed for:  
Environmental Geo-Technologies, LLC  
28470 Citrin Drive  
Romulus, MI 48174

Attention: Mr. Don Anderson

WORK REQUESTED:

Perform Barcol Hardness test on sample submitted.

DESCRIPTION OF SAMPLE:

Sample submitted was identified as a fiberglass test coupon.  
(P. O. #Credit Card).

WORK PERFORMED:

Test specimen was prepared as necessary and conditioned for a minimum of 24 hours at standard laboratory conditions prior to testing.

Barcol Hardness test was performed in accordance with the procedures of ASTM D2583-13. One specimen was tested.

RESULTS:

The following determination was made based upon the above test:

BARCOL HARDNESS


Hardness

Specimen 1

85

Specimen was returned to the client June 16, 2014.

Ghesquiere Plastic Testing, Inc.

  
M. W. Ghesquiere  
President

MWG/dm

# Ghesquiere Plastic Testing, Inc.

20450 HARPER AVENUE  
HARPER WOODS, MI 48225  
PHONE (313) 885-3535  
FAX (313) 885-1771

Report Date: June 16, 2014  
Test Date: June 13 - 16, 2014

Report #1406-78499  
Performed for:  
Environmental Geo-Technologies, LLC  
28470 Citrin Drive  
Romulus, MI 48174

Attention: Mr. Don Anderson

WORK REQUESTED:

Perform Barcol Hardness test on sample submitted.

DESCRIPTION OF SAMPLE:

Sample submitted was identified as a fiberglass test coupon.  
(P. O. #Credit Card).

WORK PERFORMED:

Test specimen was prepared as necessary and conditioned for a minimum of 24 hours at standard laboratory conditions prior to testing.

Barcol Hardness test was performed in accordance with the procedures of ASTM D2583-13. One specimen was tested.

RESULTS:


The following determination was made based upon the above test:

BARCOL HARDNESS

	<u>Hardness</u>
Specimen 1	85

Specimen was returned to the client June 16, 2014.

Ghesquiere Plastic Testing, Inc.

  
M. W. Ghesquiere  
President

MWG/dm

October 2, 2014

**• TEST REPORT •**

**PN 118325**


*PO Attn: John Frost*

**PLASTICS TESTING DEPARTMENT**


Prepared For:

John Frost  
Environmental Geo-Technologies, LLC  
28470 Citrin Drive  
Romulus, MI 48174

Prepared By:

  
Melissa Martin  
*Sr. Project Technician*

Approved By:

  
Jim Drummond  
*Physical & Plastics Testing, Manager*



An A2LA ISO 17025 Accredited Testing Laboratory — Certificate Numbers 255.01 & 255.02  
ISO 9001:2008 Registered

**ISO 9001:2008**  
Registered

\*Certificate Numbers 255.01 & 255.02

Letters and reports are for the exclusive use of the clients to whom they are addressed and shall not be reproduced, except in full, without the written permission of Akron Rubber Development Laboratory, Inc. (ARDL). The information contained herein applies to the specific material, products or processes tested or evaluated. No warranty of any kind is herein construed or implied. The liability of ARDL, Inc. shall be limited to the amount of consideration paid for services. ARDL, Inc. is ISO 17025 accredited by A2LA for the test methods listed on the attached scope.

[www.ardl.com](http://www.ardl.com)

2887 Gilchrist Rd. | Akron, Ohio 44305 | [answers@ardl.com](mailto:answers@ardl.com)  
Toll Free (800) 830-ARDL | Worldwide (330) 794-6600 | Fax (330) 794-6610



October 2, 2014

John Frost  
Environmental Geo-Technologies, LLC

Page 2 of 2  
PN118325

**SUBJECT:** Barcol Hardness on one material.  
PO# Attn: John Frost

**RECEIVED:** One small section identified as; Fiberglass Coupon.

**BARCOL HARDNESS ASTM D 2583-13a**

**Results**

Barcol Hardness, Instant

97


Prepared By:



Melissa Martin  
Sr. Project Technician

sf

Approved By:



Scott W. Yates  
Plastics Testing Assistant Manager

www.ardl.com

2887 Gilchrist Rd. | Akron, Ohio 44305 | answers@ardl.com  
Toll Free (800) 830-ARDL | Worldwide (330) 794-6600 | Fax (330) 794-6610

**BARCOL HARDNESS REPORT**


**Customer:** Republic Industrial and Energy Solutions, LLC

**Component Tested:** Test Coupon

**PO Number:** 9575553                      **Job Number:** 3415

**Calibration:**      **Disc:** 43 - 48              **Actual Reading:** 45

Barcol Readings	1	2	3	Average
Side One:	62	63	58	61
Side Two:	58	60	57	58
	<b>Overall Average:</b>			60

**Tested By:**   
(signature)

Gary Nicholson                      **Date:** 01/12/2021  
(print or type name)

**BARCOL HARDNESS REPORT**


**Customer:** Republic Industrial and Energy Solutions, LLC

**Component Tested:** Test Coupon

**PO Number:** 10159792                      **Job Number:** 3556

**Calibration:**      **Disc:** 43 - 48              **Actual Reading:** 45

Barcol Readings	1	2	3	Average
Side One:	56	60	60	59
Side Two:	60	62	62	61
	Overall Average:			60

**Tested By:**   
(signature)

Gary Nicholson  
(print or type name)

**Date:** 10/11/2021

# COOROSION MONITORING COUPONS VISUAL DESCRIPTION

**November 2021**

## **Fiberglass Coupon**

The coupon is dark orange (rust) in color with a semi-smooth texture on both sides. Its cut edges appear sanded. The coupon is free of cracks, pitting, swelling, blemishes, and corrosion. There is no obvious effect on this coupon since last month.

## **Hastelloy Coupon**

This coupon is identified as C276 with Serial Number 5. The coupon is silver in color with a lightly sandblasted texture. It is clean and free of pits, cracks, and blemishes. There is no effect to this coupon.

## **Stainless Steel Coupon**

There has been no apparent change to this coupon. Slight pitting is visible throughout coupon. There has been a significant volume of pumping to both Well #1 and Well #2. There has been a significant exposure to hazardous waste to this coupon this month.

## **MAINTENANCE**

# UIC Monthly Maintenance Log

11/18/2021	well 1&2	Removed Injection pump 1 to be sent in for maintenance
------------	----------	--

## **INJECTION FINGERPRINTS**

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-1-21
Receiving ID#	Z11012101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.T.J
Sampled by	J.M

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.16
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.09
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	62.4
Conductivity	123.4 $\mu$ S
% Solids	11.76
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.T.J



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-1-21
Receiving ID#	I11012102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.T.
Sampled by	J.T.

LAB INFORMATION	
Compatible? (RT# )	y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	
pH (S.U.)	6.78
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.7
Conductivity	29.8 mS
% Solids	1.97
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.T.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-1-21
Receiving ID#	211012103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.F.
Sampled by	DL

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	
pH (S.U.)	6.71
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.2
Conductivity	30.9 mS
% Solids	1.96
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.F.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-2-21
Receiving ID#	I11022101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	DM

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	N/A
TOC ppm (CC Waste Only)?	N/A
Flash Point (F)	> 140
pH (S.U.)	2.11
Cyanides? (mg/L)	< 30
Sulfides? (ppm)?	< 200
Specific Gravity	1.05
Physical Description	Liquid
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	69.4
Conductivity	79.3
% Solids	4.09%
Turbidity	Yes No
Color	Brown
TSS (%)	<del>0.25</del>
Radiation Screen (as needed)	No
Lab Signature/Initials	DM

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/02/2021
Receiving ID#	<del>1102</del> I 11022103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	11:03AM
Time out	
Received by	JH
Sampled by	BO

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	N/A
TOC ppm (CC Waste Only)?	N/A
Flash Point (F)	>140
pH (S.U.)	2.49
Cyanides? (mg/L)	<30
Sulfides? (ppm)?	<200
Specific Gravity	1.04
Physical Description	Liquid
Stream Consistency	<input checked="" type="radio"/> Yes <input type="radio"/> No
Oil in Sample?	Yes <input checked="" type="radio"/> No
Temperature (F)	66.8
Conductivity	56.5 mS
% Solids	0.14%
Turbidity	Yes <input checked="" type="radio"/> No
Color	Brown
TSS (%)	<0.1
Radiation Screen (as needed)	Neg
Lab Signature/Initials	BO

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-1-21
Receiving ID#	T11012104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.F.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	714
pH (S.U.)	6.69
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.8
Conductivity	32.8 mS
% Solids	2.08
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.F.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-1-21
Receiving ID#	I11012105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	JTD
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	2.91
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.06
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.2
Conductivity	89.8ms
% Solids	6.20
Turbidity	Yes No
Color	
TSS (%)	2.01
Radiation Screen (as needed)	
Lab Signature/Initials	JTD

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-2-21
Receiving ID#	R11022104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.S.J
Sampled by	M

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>110
pH (S.U.)	4.92
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.06
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	63.5
Conductivity	67.8 uS
% Solids	2.89
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.S.J

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-3-21
Receiving ID#	I11032102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	<i>JM</i>

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.67
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.03
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.9 ms
Conductivity	33.5
% Solids	2.59
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>J.M.</i>



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-2-21
Receiving ID#	Z11022105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	DW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	3.51
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.06
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.1
Conductivity	197.3 $\mu$ S
% Solids	7.23
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-3-21
Receiving ID#	I11032101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	7140
pH (S.U.)	6.20
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.09
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.9
Conductivity	42.0ms
% Solids	9.31
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/03/2021
Receiving ID#	111032103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	JH
Sampled by	BO

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	NA
TOC ppm (CC Waste Only)?	NA
Flash Point (F)	>140
pH (S.U.)	6.62
Cyanides? (mg/L)	<30
Sulfides? (ppm)?	<200
Specific Gravity	1.02
Physical Description	Liquid
Stream Consistency	<input checked="" type="radio"/> Yes <input type="radio"/> No
Oil in Sample?	<input type="radio"/> Yes <input checked="" type="radio"/> No
Temperature (F)	67.9 mS
Conductivity	32.7
% Solids	3.74%
Turbidity	<input type="radio"/> Yes <input checked="" type="radio"/> No
Color	Brown
TSS (%)	<0.1
Radiation Screen (as needed)	Neg
Lab Signature/Initials	BO

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-3-21
Receiving ID#	I11032109
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.J.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	5.24
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.06
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.4
Conductivity	>1000 us
% Solids	7.24
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.J.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-3-21
Receiving ID#	I1103 21 04
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.P.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	5.31
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.06
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.5
Conductivity	> 1000 $\mu$ S
% Solids	7.37
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.P.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-4-21
Receiving ID#	211042101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.06
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.08
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.4
Conductivity	>1000ms
% Solids	11.08
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/04/21
Receiving ID#	211042102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	587-2
Client	
Transporter	
Time in	
Time out	
Received by	JH
Sampled by	BO

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	1140
pH (S.U.)	6.65
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.03
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.3
Conductivity	>1000 $\mu$ S
% Solids	2.04
Turbidity	Yes No
Color	
TSS (%)	50.1
Radiation Screen (as needed)	
Lab Signature/Initials	JH

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-4-21
Receiving ID#	I11042103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.T
Sampled by	J.T

LAB INFORMATION	
Compatible? (RT# 2)	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.68
Cyanides? (mg/L)	230 J.T
Sulfides? (ppm)?	2.5 J.T
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.7
Conductivity	32.4 ms
% Solids	1.99
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.T



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-4-21
Receiving ID#	211042104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	RW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.68
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.8
Conductivity	31.9 uS
% Solids	2.58
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-4-21
Receiving ID#	711042105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	AA
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	
pH (S.U.)	6.80
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.7
Conductivity	31.5ms
% Solids	1.78
Turbidity	Yes No
Color	
TSS (%)	50.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11.9.21
Receiving ID#	Z11092101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.F.
Sampled by	MW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	140
pH (S.U.)	6.78
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.3
Conductivity	31.3 mS
% Solids	1.96
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	✓
Lab Signature/Initials	J.F.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-5-21
Receiving ID#	I11052102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	J.H.


LAB INFORMATION	
Compatible? (RT# )	y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.72
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	69.8
Conductivity	31.7ms
% Solids	1.72
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.


RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/05-2021
Receiving ID#	F11052103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	BB [Signature]

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.71
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	61.2
Conductivity	315
% Solids	1.7%
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	[Signature]

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11.5.21
Receiving ID#	211052104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	DAW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.70
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	63.5
Conductivity	31.9
% Solids	1.90%
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-5-21
Receiving ID#	Z11052105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	7.02
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.08
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	63.7
Conductivity	98.5
% Solids	9.23%
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-6-21
Receiving ID#	211062101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	8.28
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.08
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	63.8
Conductivity	107.7
% Solids	8.0290
Turbidity	Yes No
Color	
TSS (%)	40.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-6-21
Receiving ID#	I11062102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140°
pH (S.U.)	6.82
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	63.7
Conductivity	<del>10400</del> 31.4
% Solids	2.30%
Turbidity	Yes No
Color	
TSS (%)	40.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-6-21
Receiving ID#	Z11062103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140°
pH (S.U.)	6.92
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	
Conductivity	30.9
% Solids	1.65
Turbidity	Yes No
Color	
TSS (%)	<0.1%
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-8-21
Receiving ID#	FI1082101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.72
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	63.9
Conductivity	31.5
% Solids	1.8770
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-8-21
Receiving ID#	F-11082102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>


LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	< 140
pH (S.U.)	6.69
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	65.1
Conductivity	31.4
% Solids	2.10%
Turbidity	Yes No
Color	
TSS (%)	> 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>


RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-8-21
Receiving ID#	191082103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.74
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	64.0
Conductivity	32.1
% Solids	1.85
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-8-21
Receiving ID#	Z11082104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.75
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	63.8
Conductivity	31.7
% Solids	2.08%
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-8-21
Receiving ID#	I11082105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	11.88
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.08
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	64.4
Conductivity	103.1
% Solids	8.05
Turbidity	Yes No
Color	
TSS (%)	40.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>



RECEIVING & APPROVAL FORM


RECEIVING INFORMATION	
Date	11-9-21
Receiving ID#	I11092101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	2.18
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.04
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	64.6
Conductivity	42.4
% Solids	234
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-9-21
Receiving ID#	I11092102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.77
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	65.0
Conductivity	32.3
% Solids	2.11
Turbidity	Yes No
Color	
TSS (%)	60.1
Radiation Screen (as needed)	
Lab Signature/Initials	

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/09-2021
Receiving ID#	I11092103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	JF
Sampled by	BB

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.79
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.6
Conductivity	32.7
% Solids	1.7070
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	JF

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11.9.21
Receiving ID#	T11092104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	JF
Sampled by	JAW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.78
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	63.6
Conductivity	34.0
% Solids	2.2%
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	JF

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-9-21
Receiving ID#	I11092105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.89
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.00
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	64.6
Conductivity	33.5
% Solids	2.18%
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-10-21
Receiving ID#	Z11102101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	X
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	2140
pH (S.U.)	5.98
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.04
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	64.6
Conductivity	63.4
% Solids	3.470
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	10-10-21
Receiving ID#	T11102103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	BS

LAB INFORMATION	
Compatible? (RT# )	X
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	7.67
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	65.6
Conductivity	33.8
% Solids	1.77
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-10-21
Receiving ID#	RI1102102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.78
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	64.8
Conductivity	335
% Solids	2.21
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>


RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-10-21
Receiving ID#	I1102104
Manifest #	Line I1102104
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	DM


LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.73
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.2
Conductivity	30.8
% Solids	1.80
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	JJ



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11.10.21
Receiving ID#	I11102105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	AW

Well 1

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.72
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.2
Conductivity	31.5
% Solids	2.08
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-10-21
Receiving ID#	II1102106
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.78
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.2
Conductivity	31.7
% Solids	2.15
Turbidity	Yes No
Color	
TSS (%)	
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-11-21
Receiving ID#	211112101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	< 140
pH (S.U.)	5.91
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.04
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.1
Conductivity	60.9
% Solids	3.81
Turbidity	Yes No
Color	
TSS (%)	
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-11-21
Receiving ID#	F11112102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	<140
pH (S.U.)	6.81
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.2
Conductivity	31.4
% Solids	2.22
Turbidity	Yes No
Color	
TSS (%)	>0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/11-2021
Receiving ID#	E11112103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	BB

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.81
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.8
Conductivity	29.8
% Solids	1.61
Turbidity	Yes No
Color	
TSS (%)	> 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	JF

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/11-2021
Receiving ID#	I 11112104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	BB

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.78
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	69.1
Conductivity	30.3
% Solids	2.81
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/11-2021
Receiving ID#	I11112105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	BB

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	<140
pH (S.U.)	6.86
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.3
Conductivity	30.8
% Solids	1.93
Turbidity	Yes No
Color	
TSS (%)	>0.1
Radiation Screen (as needed)	
Lab Signature/Initials	

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-11-21
Receiving ID#	I11112106
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.92
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.3
Conductivity	30.8
% Solids	2.15
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>






RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-11-21
Receiving ID#	11112107
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>JW</i>
Sampled by	<i>AW</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	2140
pH (S.U.)	
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.9
Conductivity	31.1
% Solids	1.84
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>JW</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-11-21
Receiving ID#	I11112108
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.85
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.9
Conductivity	31.4
% Solids	2.51
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-11-21
Receiving ID#	I11112109
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.85
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.0
Conductivity	32.0
% Solids	
Turbidity	Yes No
Color	
TSS (%)	40.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-12-21
Receiving ID#	211722101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>JA</i>
Sampled by	<i>AW</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	< 140
pH (S.U.)	<del>12.16</del> 12.16
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.08
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.4
Conductivity	93.6
% Solids	8.53%
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>JA</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-12-21
Receiving ID#	211122102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>


LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.84
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.5
Conductivity	32.1
% Solids	1.86%
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>


RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-12-21
Receiving ID#	IM22103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	✓
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	<140
pH (S.U.)	6.87
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.4
Conductivity	31.5
% Solids	2.6770
Turbidity	Yes No
Color	
TSS (%)	>0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	51122104
Receiving ID#	11-12-21
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.50
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.9
Conductivity	30.4
% Solids	1.797%
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/11-2021
Receiving ID#	IL112105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	BAJ
Sampled by	BAJ

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.83
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.9
Conductivity	32.3
% Solids	2.86
Turbidity	Yes No
Color	
TSS (%)	40.1
Radiation Screen (as needed)	2
Lab Signature/Initials	BAJ






RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-12-21
Receiving ID#	I11122106
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>


LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.87
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.8
Conductivity	32.5
% Solids	2.26
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>


RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-12-21
Receiving ID#	I11122107
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	


LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.76
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.9
Conductivity	34.5
% Solids	
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	


RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-12-21
Receiving ID#	Z11122109
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.74
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.7
Conductivity	34.4
% Solids	2.55
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-12-21
Receiving ID#	11122106
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.81
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	69.3
Conductivity	33.7
% Solids	2.08
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-13-21
Receiving ID#	211132101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	AWJ

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.76
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.4
Conductivity	34.5
% Solids	2.51%
Turbidity	Yes No
Color	
TSS (%)	401
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-13-21
Receiving ID#	I0132102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	7140
pH (S.U.)	6.82
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.7
Conductivity	35.6
% Solids	
Turbidity	Yes No
Color	
TSS (%)	
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-18-21
Receiving ID#	L11132103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.87
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.7
Conductivity	35.6
% Solids	
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11.13.21
Receiving ID#	I11132104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.83
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.6
Conductivity	33.2
% Solids	2.23%
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-15-21
Receiving ID#	Z11132105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	JF
Sampled by	JAW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	7140
pH (S.U.)	6.80
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.8
Conductivity	32.8
% Solids	3.37%
Turbidity	Yes No
Color	
TSS (%)	40.1
Radiation Screen (as needed)	
Lab Signature/Initials	JF

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	7 I 11152101
Receiving ID#	11/15-2021
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	JF
Sampled by	BB

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	Y
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.89
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.0
Conductivity	31.1
% Solids	2.48
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	JF

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/15-2021
Receiving ID#	I 11152102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	BB [Signature]

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.85
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.0
Conductivity	31.7
% Solids	0.18%
Turbidity	Yes No
Color	
TSS (%)	0.1
Radiation Screen (as needed)	
Lab Signature/Initials	[Signature]

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/15-2021
Receiving ID#	I11152103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	BBJF

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	<140
pH (S.U.)	6.81
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.0
Conductivity	31.6
% Solids	2.36%
Turbidity	Yes No
Color	
TSS (%)	
Radiation Screen (as needed)	
Lab Signature/Initials	BBJF

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-15-21
Receiving ID#	Z11152104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.76
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.0
Conductivity	33.3
% Solids	1.47
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-18-21
Receiving ID#	211182105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	10.52
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.06
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.5
Conductivity	76.5
% Solids	5.53%
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-16-21
Receiving ID#	I 11162101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	AW <i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	<140
pH (S.U.)	1.38
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.8
Conductivity	56.0
% Solids	1.9490
Turbidity	Yes No
Color	
TSS (%)	70.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/16-2021
Receiving ID#	I11162102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	JF
Sampled by	BB

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.76
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	69.0
Conductivity	33.3
% Solids	2.02%
Turbidity	Yes No
Color	
TSS (%)	60.1
Radiation Screen (as needed)	
Lab Signature/Initials	JF



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	1/16-2021
Receiving ID#	I11162103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	BB [Signature]

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	20140
pH (S.U.)	6.88
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.3
Conductivity	32.9
% Solids	2.30%
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	[Signature]

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/16-2021
Receiving ID#	I 111621 04
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	BB JF

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.86
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.5
Conductivity	32.4
% Solids	1.81%
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	JF

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-16-21
Receiving ID#	Z11162108
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	AWJ

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.83
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.5
Conductivity	33.7
% Solids	1.94%
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	JF

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-16-21
Receiving ID#	RI1162106
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	AW [Signature]

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	9.02
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	65.7
Conductivity	3.79
% Solids	1.54%
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	[Signature]

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-17-21
Receiving ID#	Z11172101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	8.71
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.08
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.6
Conductivity	116.7
% Solids	8.04%
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-17-21
Receiving ID#	21172102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.87
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.3
Conductivity	33.1
% Solids	2.03%
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/17-2021
Receiving ID#	E11172103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	BB [Signature]

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.93
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.8
Conductivity	32.1
% Solids	2.10%
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	[Signature]

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/17-2021
Receiving ID#	E11172104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	BRJ

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.88
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.8
Conductivity	32.5
% Solids	
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	JF



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-17-21
Receiving ID#	Z11172105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.83
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.8
Conductivity	28.6
% Solids	1.64
Turbidity	Yes No
Color	
TSS (%)	
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-17-21
Receiving ID#	IL1172106
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	AWJ

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.96
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	64.7
Conductivity	29.0
% Solids	2.35
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	JF

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-18-21
Receiving ID#	Z11182101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	AWW <i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	2140
pH (S.U.)	9.03
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.10
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.1
Conductivity	115.1
% Solids	9.23%
Turbidity	Yes No
Color	
TSS (%)	40.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-18-21
Receiving ID#	211182102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	5.89
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	65.9
Conductivity	30.1
% Solids	2.05
Turbidity	Yes No
Color	
TSS (%)	40.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-18-21
Receiving ID#	I 11182103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	2140
pH (S.U.)	5.02
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.8
Conductivity	30.9
% Solids	1.7370
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-18-21
Receiving ID#	Z11182105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	ALJF

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	5.91
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.6
Conductivity	27.8
% Solids	1.79
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11.18.21
Receiving ID#	211182106
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	Am JF

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.10
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	67.0
Conductivity	269
% Solids	1.74
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	JF

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-19-21
Receiving ID#	B11192103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	TG [Signature]
Sampled by	TG [Signature]

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	7.87
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	65.8
Conductivity	31.2
% Solids	1.64%
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	[Signature]



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-19-21
Receiving ID#	Z11192101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.36
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.06
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.2
Conductivity	81.5
% Solids	53.8%
Turbidity	Yes No
Color	
TSS (%)	401
Radiation Screen (as needed)	
Lab Signature/Initials	AW

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-19-21
Receiving ID#	I11192102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.14
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	65.8
Conductivity	26.7
% Solids	22870
Turbidity	Yes No
Color	
TSS (%)	40.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>


RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-19-21
Receiving ID#	211192103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	7140
pH (S.U.)	6.26
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	65.0
Conductivity	26.0
% Solids	2.30%
Turbidity	Yes No
Color	
TSS (%)	2.01
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-19-21
Receiving ID#	I11192104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	DM

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.50
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	60.6
Conductivity	26.6
% Solids	2.23%
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-19-21
Receiving ID#	7111921 OS
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	7.24
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.0
Conductivity	27.7 mS
% Solids	1.69
Turbidity	Yes No
Color	
TSS (%)	10.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-19-21
Receiving ID#	Z11192106
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.T.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	7.14
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	65.8
Conductivity	26.5 uS
% Solids	1.71
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.T.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-20-21
Receiving ID#	Z11202101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.J.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	7.31
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.0
Conductivity	273ms
% Solids	1.79
Turbidity	Yes No
Color	
TSS (%)	40.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.J.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-20-21
Receiving ID#	Z11202102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	JH
Sampled by	DM

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	7.33
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.0
Conductivity	22.5 mS
% Solids	1.91
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	JH



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-20-21
Receiving ID#	411202103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	DB

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	7.29
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.0
Conductivity	27.6 mS
% Solids	1.75
Turbidity	Yes No
Color	
TSS (%)	50.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-22-21
Receiving ID#	II222101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.T.
Sampled by	DM

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	7.40
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	65.4
Conductivity	26.7 ms
% Solids	1.80
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.T.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-22-21
Receiving ID#	T11222102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.J.
Sampled by	DM

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 14
pH (S.U.)	7.28
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	64.7
Conductivity	22.0ms
% Solids	1.67
Turbidity	Yes No
Color	
TSS (%)	50.7
Radiation Screen (as needed)	
Lab Signature/Initials	J.J.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-22-21
Receiving ID#	11222103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	T.H.
Sampled by	

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.85
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	62.9
Conductivity	27.1 ms
% Solids	1.86
Turbidity	Yes No
Color	
TSS (%)	LOU
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/22/21
Receiving ID#	112221 64
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H
Sampled by	

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.70
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.01
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.1
Conductivity	27.8 mg
% Solids	1.92
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11.22.21
Receiving ID#	Z11222108
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.T.R.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	5.99
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.3
Conductivity	31.3 mS
% Solids	1.99
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-23-21
Receiving ID#	I11232101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.J
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	5.14
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.05
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.1
Conductivity	82.7 mS
% Solids	6.13
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.J

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-23-21
Receiving ID#	JH232102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	DM

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	
pH (S.U.)	5.97
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.7
Conductivity	31.2 uS
% Solids	2.14
Turbidity	Yes No
Color	
TSS (%)	40.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-23-21
Receiving ID#	11232104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	<i>[Signature]</i>
Sampled by	<i>[Signature]</i>

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	5.65
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	63.8
Conductivity	32.7 mS
% Solids	2.38
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	<i>[Signature]</i>

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-123-21
Receiving ID#	I11232103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.F.
Sampled by	J.F.
LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	5.80
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	66.4
Conductivity	31.3 mS
% Solids	2.10
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.F.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-23-21
Receiving ID#	211232105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	5.94
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	69.8
Conductivity	34.2 mS
% Solids	2.35
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-24-21
Receiving ID#	Z11242101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	3.27
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.05
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	69.1
Conductivity	85.1 mS
% Solids	6.13
Turbidity	Yes No
Color	
TSS (%)	< 6.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-24-21
Receiving ID#	I11242102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.J.
Sampled by	J.

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	7140
pH (S.U.)	6.23
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	70.2
Conductivity	34.5
% Solids	2.10
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.J.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-24-21
Receiving ID#	IN 242103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.F.
Sampled by	DM

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.45
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	69.4
Conductivity	34.9 uS
% Solids	2.20
Turbidity	Yes No
Color	
TSS (%)	40.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.F.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-24-21
Receiving ID#	IL242105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.T.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.65
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	70.3
Conductivity	34.9 mS
% Solids	2.30
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.T.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-26-21
Receiving ID#	II1262101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	J.H.

LAB INFORMATION	
Compatible? (RT# )	X
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	1140
pH (S.U.)	6.82
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	70.1
Conductivity	35.3 mS
% Solids	2.08
Turbidity	Yes No
Color	
TSS (%)	16.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-26-21
Receiving ID#	11262107
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.J.
Sampled by	J.F.

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	2140
pH (S.U.)	6.91
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	69.3
Conductivity	35.1 mS
% Solids	2.23
Turbidity	Yes No
Color	
TSS (%)	LO
Radiation Screen (as needed)	
Lab Signature/Initials	J.J.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-24-21
Receiving ID#	11242104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	2140
pH (S.U.)	6.50
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	70.0
Conductivity	355 us
% Solids	2.03
Turbidity	Yes No
Color	
TSS (%)	50.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-27-21
Receiving ID#	II1222101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.F.
Sampled by	J.F.

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.97
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	70.0
Conductivity	35.605
% Solids	2.12
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.F.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-27-21
Receiving ID#	211272102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.95
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	70.5
Conductivity	36.1 mS
% Solids	2.36
Turbidity	Yes No
Color	
TSS (%)	LOI
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11.28.21
Receiving ID#	11282101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.95
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	70.3
Conductivity	362.05
% Solids	2.12
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-28-21
Receiving ID#	11282102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	J.H.

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.87
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	69.5
Conductivity	34.9 mS
% Solids	2.00
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-28-21
Receiving ID#	I11282102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.T.
Sampled by	J.T.

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>14
pH (S.U.)	6.85
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.3
Conductivity	34.5 $\mu$ S
% Solids	2.13
Turbidity	Yes No
Color	
TSS (%)	40.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-29-21
Receiving ID#	I11292101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.J.
Sampled by	JM

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.88
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	69.3
Conductivity	34.6ms
% Solids	1.88
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.J.



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/29-2021
Receiving ID#	I11292103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.J.
Sampled by	BB

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	
pH (S.U.)	6.85
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	71.2
Conductivity	35.0 mS
% Solids	2.13
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.J.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-29-21
Receiving ID#	Z11292104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	
pH (S.U.)	6.61
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	70.4
Conductivity	35.2 mS
% Solids	1.90
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.A.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-29-21
Receiving ID#	Z1129210S
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	
pH (S.U.)	6.56
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	70.0
Conductivity	35.2 mS
% Solids	2.62
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.H

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-30-21
Receiving ID#	211302101
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	JH
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	
pH (S.U.)	7.28
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.07
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	70.5
Conductivity	84.5 μS
% Solids	10.20
Turbidity	Yes No
Color	
TSS (%)	20.1
Radiation Screen (as needed)	
Lab Signature/Initials	JH

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11/30-2021
Receiving ID#	I11302102
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.H
Sampled by	BR

LAB INFORMATION	
Compatible? (RT# )	Y
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	
pH (S.U.)	6.62
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.07
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	68.7
Conductivity	36.0 uS
% Solids	2.31
Turbidity	Yes No
Color	
TSS (%)	LOU
Radiation Screen (as needed)	
Lab Signature/Initials	J.H

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-30-21
Receiving ID#	I11302103
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.T.
Sampled by	J.T.

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	6.59
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	69.3
Conductivity	36.6 mS
% Solids	2.31
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.T.

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11-30-21
Receiving ID#	I11302104
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	JTJ
Sampled by	JM

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>140
pH (S.U.)	6.70
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	70.7
Conductivity	369
% Solids	2.01
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	JTJ

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11.30.21
Receiving ID#	Z11302105
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.T.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	>148
pH (S.U.)	6.75
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.02
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	70.2
Conductivity	36.3 mS
% Solids	2.17
Turbidity	Yes No
Color	
TSS (%)	<0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.T.



RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	11.30.21
Receiving ID#	Z11302106
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	
Client	
Transporter	
Time in	
Time out	
Received by	J.T.
Sampled by	AW

LAB INFORMATION	
Compatible? (RT# )	
PCBs (ppm) (Oily Waste Only)?	
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 148
pH (S.U.)	3.82
Cyanides? (mg/L)	
Sulfides? (ppm)?	
Specific Gravity	1.07
Physical Description	
Stream Consistency	Yes No
Oil in Sample?	Yes No
Temperature (F)	70.5
Conductivity	55.9ms
% Solids	0.78
Turbidity	Yes No
Color	
TSS (%)	< 0.1
Radiation Screen (as needed)	
Lab Signature/Initials	J.T.

## **WASTE PROFILES**



# Republic Services

18500 N. Allied Way, Phoenix, AZ 85054

## SPECIAL WASTE DEPARTMENT DECISION

	Waste Profile # 64402135450	Expiration Date 3/19/2022	
<b>I. Decision Request:</b>	<input checked="" type="checkbox"/> Initial	<input type="checkbox"/> Recertification	<input type="checkbox"/> Change
<b>Disposal Facility:</b> 6440 - Detroit Industrial Well			
<b>Generator Name:</b> NETWORK MATERIALS & RESOURCES INC.			
<b>Generator Site Address:</b> 31 GOLDEN GATE COURT			
<b>City:</b> TORONTO	<b>County:</b> <input type="text"/>	<b>State:</b> ON	<b>Zip:</b> <input type="text"/>
<b>Name of Waste:</b> RAFFINATE			
<b>Estimated Annual Volume:</b> 500,000 Gallons			

**II. Special Waste Department Decision:**       Approved     Rejected

**Management Method(s):**       Landfill     Solidification     Bioremediation     Deep Well     Transfer Facility


**Problematic Special Waste according to Republic?**       Yes     No

**If yes, which one?**     

**Approved by Special Waste Review Committee?**       Yes     No     Not Applicable

### Precautions, Conditions or Limitations on Approval

The site must ensure that all pre-acceptance and verification analytical is performed in accordance with the site's permit requirements prior to acceptance and disposal of the profiled waste.


**Special Waste Analyst Signature:**   
**Date:** 10/29/2021

**Name (Printed):** KEITH DIAMANTI

**III. Facility Decision:**       Approved     Rejected

### Precautions, Conditions or Limitations on Approval

By signing below, the General Manager or Designee agrees that a fully executed Special Waste Service Agreement is on file for this profile and that the special waste file is complete.

**General Manager or Designee:**   
**Date:** 11-1-21

**Name (Printed):** John Frost



# Republic Services

18500 N. Allied Way, Phoenix, AZ 85054

# FAX

## INCOMPLETE FILE TRANSMITTAL

<b>TO:</b> Samantha Barrera	<b>LOG NO.:</b> 64402135450
<b>FAX:</b>	<b>File Received:</b> 10/29/2021
<b>From:</b> Special Waste Dept.	<b>Response Date:</b> 10/29/2021
<b>Re:</b> NETWORK MATERIALS & RESOURCES INC. / RAFFINATE	

SECTION I	SECTION II	SECTION III	SECTION IV	SECTION V	SECTION VI
<input type="checkbox"/> DisposalFacility	<input type="checkbox"/> TransporterName	<input type="checkbox"/> NameOfWaste	<input type="checkbox"/> USEPA	<input type="checkbox"/> CharacteristicComponents	<input type="checkbox"/> GenAuthSignature
<input type="checkbox"/> GeneratorName	<input type="checkbox"/> TransporterSiteAddress	<input type="checkbox"/> ProcessGeneratingWaste	<input type="checkbox"/> SampleDate	<input type="checkbox"/> FreeLiquids	<input type="checkbox"/> GenCoName
<input type="checkbox"/> GeneratorSiteAddress	<input type="checkbox"/> TransporterCityStateZip	<input type="checkbox"/> TypeOfWaste	<input type="checkbox"/> CompositeGrab	<input type="checkbox"/> YesNo	<input type="checkbox"/> NoStateLetter
<input type="checkbox"/> GeneratorCityStateZip	<input type="checkbox"/> TransporterMailingAddress	<input type="checkbox"/> PhysicalState	<input type="checkbox"/> SampleID	<input type="checkbox"/> pH_Flash	<input type="checkbox"/> Name_Title
<input type="checkbox"/> GeneratorMailingAddress	<input type="checkbox"/> TransporterContactName	<input type="checkbox"/> MethodOfShipment			<input type="checkbox"/> SignatureDate
<input type="checkbox"/> GeneratorContactName	<input type="checkbox"/> TransporterTelFAX	<input type="checkbox"/> EstimatedAnnualVolume			
<input type="checkbox"/> GeneratorTelFAX		<input type="checkbox"/> Frequency			
<input type="checkbox"/> GeneratorStateID		<input type="checkbox"/> DisposalConsideration			
<input type="checkbox"/> WasteCodeTexas					

ANALYTICALS	TCLP TOTAL METALS	TCLP VOLATILES	TCLP SEMI-VOLATILES	PESTICIDES / HERBICIDE	
<input type="checkbox"/> TotalCyanide	<input type="checkbox"/> Arsenic	<input type="checkbox"/> Benzene	<input type="checkbox"/> Cresols	<input type="checkbox"/> Chlordane	<input type="checkbox"/> LabLetterhead
<input type="checkbox"/> ReactiveCyanide	<input type="checkbox"/> Barium	<input type="checkbox"/> CarbonTetrachloride	<input type="checkbox"/> DichlorobenzeneOne	<input type="checkbox"/> Endrin	<input type="checkbox"/> ChainOfCustody
<input type="checkbox"/> TotalSulfide	<input type="checkbox"/> Cadmium	<input type="checkbox"/> Chlorobenzene	<input type="checkbox"/> DinitrotolueneTwo	<input type="checkbox"/> Heptachlor	<input type="checkbox"/> NoLabSignature
<input type="checkbox"/> ReactiveSulfide	<input type="checkbox"/> Chromium	<input type="checkbox"/> Chloroform	<input type="checkbox"/> Hexachlorobenzene	<input type="checkbox"/> HeptachlorEpoxide	<input type="checkbox"/> ReportOneYearOldPlus
<input type="checkbox"/> TotalPCB	<input type="checkbox"/> Copper	<input type="checkbox"/> DichloroethaneOne	<input type="checkbox"/> Nitrobenzene	<input type="checkbox"/> Lindane	<input type="checkbox"/> NoThirdPartyLab
<input type="checkbox"/> TOX_EOX	<input type="checkbox"/> Lead	<input type="checkbox"/> DichloroethyleneTwo	<input type="checkbox"/> Pentachlorophenol	<input type="checkbox"/> Methoxychlor	<input type="checkbox"/> MissingReportPages
<input type="checkbox"/> Phenols	<input type="checkbox"/> Mercury	<input type="checkbox"/> MethylEthylKetone	<input type="checkbox"/> Pyridine	<input type="checkbox"/> Toxaphene	<input type="checkbox"/> MissingMSDSPages
<input type="checkbox"/> FlashPoint	<input type="checkbox"/> Selenium	<input type="checkbox"/> Tetrachloroethylene	<input type="checkbox"/> TrichlorophenolFive	<input type="checkbox"/> TwoFourD	<input type="checkbox"/> TotalSulfates
<input type="checkbox"/> pH	<input type="checkbox"/> Silver	<input type="checkbox"/> Trichloroethylene	<input type="checkbox"/> TrichlorophenolSix	<input type="checkbox"/> TwoFourFiveTP	<input type="checkbox"/> TotalSulfur
<input type="checkbox"/> PaintFilter	<input type="checkbox"/> Zinc	<input type="checkbox"/> VinylChloride			<input type="checkbox"/> WrongProfile
<input type="checkbox"/> TPH					
<input type="checkbox"/> BTEX					<input checked="" type="checkbox"/> GeneratorIncomplete

**Notes:**  
 Generator answered Yes to the regulated by TSCA (PCB) question. This doesn't make sense.  
 Sample No section needs to be completed. Keith

**Republic Industrial and Energy Solutions, LLC**

28470 Citrin Dr, Romulus, MI 48174. Telephone 734-946 1000, Fax 734 946 1002

**GENERATOR WASTE PROFILE**

Profile # 64402135450

**GENERATOR INFORMATION**

Name: Network Materials & Resources Inc. USEPA ID # MIR000018055  
 Facility Address: 31 Golden Gate Court SIC/NAICS Code: State Code: NAICS 541620, 582210  
 City: Toronto State: ON Zip Code: M1P 3A4  
 Contact: Mike Aston Title: General Manager Phone: ( 1 5 ) 299-0116 Fax: ( 1 5 ) 299-9649

**BILLING INFORMATION**

SAME AS ABOVE

Company Name: Network Environmental Services Inc.  
 Address: 31 Golden Gate Court  
 City: Toronto State: ON Zip Code: M1P 3A4  
 Attention: Giles Goulding Title: Controller Phone: ( 1 5 ) 299-0116 Fax: ( 1 5 ) 299-9649

**WASTE INFORMATION**

Name of Waste/Common Chemical Name: Raffinate  
 Process Generating Waste (Please be specific, incomplete information may delay the approval process):  
Leaching of Gallium-Arsenate chips for Gallium-recovery

**USEPA / STATE WASTE IDENTIFICATION**

- This waste is considered to be:  Non Hazardous Liquid Industrial Waste  Hazardous Waste
- Regulated by TSCA?  Yes  No (PCBs, etc.) MA 29-10-2021
- List ALL Applicable Waste Codes: D002, D004, D007, D010

**PHYSICAL CHARACTERISTICS OF WASTE**

<b>Color:</b> <input checked="" type="checkbox"/> White/Clear <input type="checkbox"/> Black/Brown <input type="checkbox"/> Other	<b>Suspended Solids</b> <input checked="" type="checkbox"/> 0-1 % <input type="checkbox"/> 3-5 % <input type="checkbox"/> 1-3 % <input type="checkbox"/> > 5%	<b>Layers:</b> <input type="checkbox"/> Multi layered <input checked="" type="checkbox"/> Bi-Layered <input type="checkbox"/> Single Phase	<b>Specific Gravity:</b> <input type="checkbox"/> <0.8 <input checked="" type="checkbox"/> 1.0-1.2 <input type="checkbox"/> 0.8-1.0 <input type="checkbox"/> 1.3-1.4 Exact / Other <input type="text"/>
--	---	---	--

pH:  <NA  < 2  2-4  4-6  6-8  8-10  10-12.5  >12.5  
 Liquid Flash Point:  <73°F  73-100°F  101-140°F  141-200°F  >200°F  None  Closed Cup  Open Cup  
 VOC CONCENTRATION - 0 PPM (MUST BE COMPLETED)

TOTAL COMPOSITION OF WASTE - MUST BE EQUAL TO OR GREATER THAN 100% (LIST EACH CONSTITUENT <math>\leq 1\%</math>)

CONSTITUENT	MAX	MIN	CONSTITUENT	MAX	MIN
water	80	99			
Sulfuric acid	0	15			
Hydrochloric Acid	0	5			

Metals: Indicate if this waste contains any of the following metals  
 If Generator knowledge-provide backup  Lab Analysis  Generator Knowledge

TCLP  TOTAL

	Not Present	Concentration	Not Present	Concentration							
PCB	<input checked="" type="checkbox"/>	ppm	Aromatic Amine	<input checked="" type="checkbox"/>	ppm	Arsenic (As)	D004	<input type="checkbox"/>	<5	ppm	ppm
Dioxins	<input checked="" type="checkbox"/>	ppm	Pesticides	<input checked="" type="checkbox"/>	ppm	Barium (Ba)	D005	<input checked="" type="checkbox"/>	<100	ppm	ppm
Cyanides Reactive	<input checked="" type="checkbox"/>	ppm	Rodenticides	<input checked="" type="checkbox"/>	ppm	Cadmium (Cd)	D006	<input checked="" type="checkbox"/>	<1	ppm	ppm
Cyanides Total	<input checked="" type="checkbox"/>	ppm	Fungicides	<input checked="" type="checkbox"/>	ppm	Chromium (Cr)	D007	<input checked="" type="checkbox"/>	<5	ppm	ppm
Sulfides Reactive	<input checked="" type="checkbox"/>	ppm				Lead (Pb)	D008	<input type="checkbox"/>	<5	ppm	ppm
Sulfides Total	<input checked="" type="checkbox"/>	ppm				Mercury (Hg)	D009	<input checked="" type="checkbox"/>	<0.2	ppm	ppm
						Selenium (Se)	D010	<input type="checkbox"/>	<1	ppm	ppm
						Silver (Ag)	D011	<input checked="" type="checkbox"/>	<5	ppm	ppm

TCLP Organics D012 — D043 above regulatory limits: Present  Not Present

IS WASTE ANY OF THE FOLLOWING? *At Least One Box Must Be Checked:*  
 Radioactive  Water Reactive  Oxidizer  Shock Sensitive  Reactive (other)  DOT Explosives  
 NIOSH Human-Positive Carcinogens  NESHAP Wastes (Benzene, etc.)  Biological  None Apply

**SHIPPING INFORMATION**

1. Is this a DOT Hazardous Material (49CFR 172.101 & 173 Subpart D)?  Yes  No  
 2. Reportable Quantity (RQ) in pounds 10  
 3. DOT Shipping Name UN3264, Corrosive Liquid, Acidic, Inorganic, nos (Waste) Hazard Class 8 UN/NA 3264  
 PG II ERG 154 Hazardous Constituents for "n.o.s." sulfuric acid, hydrochloric acid  
 4. Method of Shipment:  Bulk Tanker  Vac truck  Rail Car  Drums  Totes  
 5. Number of Units to Ship Now 5,000 USG 6. Anticipated Volume / Units per Year: 500,000 USG or  One-Time  
 6. Special Handling Requirements including PPE:

**CERTIFICATION STATEMENT**

I hereby represent and warrant that I have personally examined and am familiar with the information contained and submitted in this and all attached documents. Based on my inquiry and personal knowledge of those individuals responsible for supplying or obtaining the information, the information contained herein is true, accurate, and complete to the best of my knowledge and belief. Furthermore, no material fact has been omitted as to make this information misleading. I understand that others may rely on this representation and warranty in the handling and processing of the waste material described herein.

If this box is checked  I request Republic Industrial & Energy Solutions not to correct any inconsistencies. Any corrections Republic Industrial & Energy Solutions makes will be consistent with the results of the sample characterization and/or regulatory requirements.

Printed Name: Mike Aston Title: General Manager  
 Generator's Signature: Mike Aston Date: 15-10-2021

**GENERATOR'S CHAIN OF CUSTODY RECORD INSTRUCTIONS:** PLEASE collect a representative 1-quart sample of the waste described in the above referenced GENERATOR'S WASTE PROFILE REPORT using an appropriate container. A representative sample is one obtained using any of the applicable sampling methods cited in 40 CFR 261-Appendix 1. Fill in the sampling information in the spaces provided below. If you have problems obtaining a representative sample of your waste, please contact your Republic Industrial & Energy Solutions representative.

1. grab 2. tank  
 SAMPLING METHOD COLLECTION POINT  
 3. Mike Aston, Network  
 SAMPLE COLLECTOR'S NAME, TITLE, EMPLOYER  
 4. Sample No. CA 12317-MAR21 M.A. 29-10-2021 Preservation: Yes  No   
 5. CHAIN OF CUSTODY Each person who handles the sample must sign below when the sample passes from one to another.

Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time
<u>Mike Aston</u>	<u>oct 8, 2021</u>				

RECEIVING & APPROVAL FORM

RECEIVING INFORMATION	
Date	10/19/21
Receiving ID#	Raffinate
Manifest #	Line
Land Ban Cert included	Yes No
EGT Approval #	
Generator	Network MTL's Resources
Client	
Transporter	
Time in	
Time out	
Received by	J.H.
Sampled by	C. J. [Signature]

LAB INFORMATION	
Compatible? (RT# )	Y 4 out of 6 wastestreams
PCBs (ppm) (Oily Waste Only)?	N/A
TOC ppm (CC Waste Only)?	
Flash Point (F)	> 140
pH (S.U.)	1.73
Cyanides? (mg/L)	< 30
Sulfides? (ppm)?	< 200
Specific Gravity	1.15
Physical Description	Liquid
Stream Consistency	(Yes) No
Oil in Sample?	Yes (No)
Temperature (F)	71.3
Conductivity	130.6 umS
% Solids	15.14
Turbidity	(Yes) No
Color	White
TSS (%)	< 0.1
Radiation Screen (as needed)	Neg.
Lab Signature/Initials	J.H.

(See Attached Lab Notes)



SGS Canada Inc.  
 P.O. Box 4300 - 185 Concession St.  
 Lakefield - Ontario - K0L 2H0  
 Phone: 705-652-2000 FAX: 705-652-6365

19-March-2021

**Network Environmental Services Inc**

Attn : Mike Aston

Date Rec. : 09 March 2021  
 LR Report: CA12317-MAR21

31 Golden Gate Court  
 Scarborough, ON  
 M1P 3A4, Canada

Copy: #1

Phone: 416-299-0116  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Analysis	3: Analysis Completed Date	4: Analysis Completed Time	5: TC 221 H2SO4 SG 1.145
Sample Date & Time			Date:NA
Temp Upon Receipt [°C]	---	---	9.0
Acidity [mg/L as CaCO3]	12-Mar-21	11:15	244000
Cl [mg/L]	19-Mar-21	12:27	< 100
SO4 [mg/L]	19-Mar-21	15:45	220000
Ag (tot) [mg/L]	17-Mar-21	16:00	< 0.8
Al (tot) [mg/L]	17-Mar-21	16:00	46.8
As (tot) [mg/L]	17-Mar-21	16:00	< 0.1
Ba (tot) [mg/L]	17-Mar-21	16:00	0.010
Be (tot) [mg/L]	17-Mar-21	16:00	< 0.009
B (tot) [mg/L]	17-Mar-21	16:00	56.1
Bi (tot) [mg/L]	17-Mar-21	16:00	< 0.5
Ca (tot) [mg/L]	17-Mar-21	16:00	98
Cd (tot) [mg/L]	17-Mar-21	16:00	0.82
Co (tot) [mg/L]	17-Mar-21	16:00	0.09
Cr (tot) [mg/L]	17-Mar-21	16:00	2.51
Cu (tot) [mg/L]	17-Mar-21	16:00	12.7
Fe (tot) [mg/L]	17-Mar-21	16:00	105
K (tot) [mg/L]	17-Mar-21	16:00	4.12
Li (tot) [mg/L]	17-Mar-21	16:00	< 1
Mg (tot) [mg/L]	17-Mar-21	16:00	92.2
Mn (tot) [mg/L]	17-Mar-21	16:00	0.320
Mo (tot) [mg/L]	17-Mar-21	16:00	0.3
Na (tot) [mg/L]	17-Mar-21	16:00	1958
Ni (tot) [mg/L]	17-Mar-21	16:00	2.11
P (tot) [mg/L]	17-Mar-21	16:00	5.21
Pb (tot) [mg/L]	17-Mar-21	16:00	7.3





SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.


Lakefield - Ontario - KOL 2H0

Phone: 705-652-2000 FAX: 705-652-6365

LR Report : CA12317-MAR21

Analysis	3: Analysis Completed Date	4: Analysis Completed Time	5: TC 221 H2SO4 SG 1.145
S (tot) [mg/L]	17-Mar-21	16:00	75293
Sb (tot) [mg/L]	17-Mar-21	16:00	28
Se (tot) [mg/L]	17-Mar-21	16:00	0.7
Si (tot) [mg/L]	17-Mar-21	16:00	19
Sn (tot) [mg/L]	17-Mar-21	16:00	7.4
Sr (tot) [mg/L]	17-Mar-21	16:00	< 0.002
Ti (tot) [mg/L]	17-Mar-21	16:00	< 0.05
Tl (tot) [mg/L]	17-Mar-21	16:00	< 0.9
U (tot) [mg/L]	17-Mar-21	16:00	< 1
V (tot) [mg/L]	17-Mar-21	16:00	0.06
W (tot) [mg/L]	17-Mar-21	16:00	< 0.1
Y (tot) [mg/L]	17-Mar-21	16:00	< 0.005
Zn (tot) [mg/L]	17-Mar-21	16:00	10.1

*Catharine Arnold*



Catharine Arnold, B.Sc., C.Chem  
Project Specialist,  
Environment, Health & Safety